

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load, Operating forces, Mechanical properties



Test Report

No. 15-001232-PR03

(PB-A01-0203-en-01)

| | |
|--------------------------------------|---|
| Client | CKM Extrusion Sp. z o.o. Ul. Kanalowa 2 98-220 Zdunska Wola Poland |
| Product | 5-sash tilt and turn window with fixed mullions |
| Designation | System designation: SYSTEM R2 / T-COMFORT |
| Performance-relevant product details | Material: PVC-U / white |
| Overall dimensions (WxH) | 2,700 mm x 1,910 mm |
| Special features | - / - |

Basis

EN 14351-1:2006+A1:2010

Test standards:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2003-11

EN 12211:2000-06

EN 14608:2004-06

EN 14609:2004-06

Corresponds to the national standards (e. g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer type testing test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturers own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 27 pages.

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 5A

Resistance to wind load according EN 12210:1999-11/AC:2002-08



Class C3 / B3

Operating forces according to EN 13115:2001-07



Class 1

Mechanical propertiel according to EN 13115:2001-07



Class 4

ift Rosenheim

31.07.2015

Michael Breckl-Stock, M.Eng., Dipl.-Ing. (FH)
Deputy Head of Testing Department
Construction Product Testing

Thomas Krichbaumer
Operating Testing Officer
Construction Product Testing