

Evidence of Performance

Resistance to wind load, Watertightness, Air permeability



Test Report

No. 13-000323-PR02

(PB-A01-02-en-01)

Client	BUDVAR Centrum SA ul. Przemyslowa 36 98-220 Zdunska Wola Poland
Product	Five leaf tilt and turn window with fixed mullions
Designation	System designation: T-Passive
Performance-relevant product details	Material: PVC-U / white
Overall dimensions (W x H)	2,699 mm x 1,911 mm
Special features	- / -

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2003-11

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 6A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C3 / B3

ift Rosenheim

15.05.2013

Michael Breckl-Stock, M.Eng., Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Components

Thomas Krichbaumer
Operating Testing Officer
Tightness & Wind Load

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 20 pages.